

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI009341
DATE: 02/11/2008
CERTIFICATION PROGRAM: Structural
COMPANY: Inteplast Group
CODE: I-1258-1


The "Notice of Product Certification" is valid only when Administrator's Seal is applied to the upper left hand portion of this form and a certification label is applied to the product. This certification seal represents product conformity to the applicable specification and that all certification criteria has been satisfied.

The product described below is approved for listing in the next published issue of the Directory of Certified Products. Please review, and advise NAMI immediately if data, as shown, requires corrections.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Inteplast Group 101 Inteplast Boulevard Lolita, TX 77971	Series "Inteplast Shutter 16mm White Polypropylene Single Storm Panel" Configuration: O Material: Polypropylene-16mm (0.625") Overall Size: W-1219mm(48") H-2438mm(96")

SPECIFICATION	PRODUCT RATING
ASTM E330-02 ASTM E1886-02/E1996-02	Design Pressure: +70.0/-70.0 psf Wind Zone 4-Missile Level D

Product Tested By: Certified Testing Laboratories
 Report No: CTLA-1767W
 Expiration Date: November 30, 2011

Administrator's Signature: _____ 

**NATIONAL ACCREDITATION AND
 MANAGEMENT INSTITUTE, INC.**
 11870 Merchants Walk Suite 202
 Newport News, VA 23606
 TEL: (757) 594-8658
 FAX: (757) 594-8659

RJQ Engineering, Inc.
Consulting Structural Engineer
195 Wekiwa Springs Rd. Ste. 222
Longwood, FL 32779
(407)681-6595; Fx. (407)681-6545
e-mail: RQUIROGA@AOL.COM

December 21, 2007

Mr. Ted Berman
Ted Berman, LLC
5401 Collins Ave., CU11-C
Miami Beach, FL 33140

Ref: **Rational Analysis Verification**

Sub: FL10333 (Inteplast Group – 16mm Intepro Storm Panel).


Dear Mr. Berman,

I performed a Technical Review of the anchorage Rational Analysis originated by Mr. Douglas J. McDougal, P.E with Florida State Professional Engineer License#-28392 relating to the above referenced Florida Product Approval Application and found it to be in accordance with the 2004 Florida Building Code and the 2005, 2006 and 2007 Supplements.

Additionally, I would like to state that I do not have, nor will acquire, a financial interest in any company manufacturing or distributing the product(s) for which the reports are being issued.

Furthermore, I do not have, nor will acquire, a financial interest in any other entity involved in the approval process of the above referenced application.

Sincerely,



Mr. Rene J. Quiroga, P.E.
Florida State Professional Engineer License#-47946

Cc: \ Eng. File.